

TABEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 1 sur 7)

CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE											COMPARTIMENTAGE						EVACUATION									
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPEURE SONORISATION / PROJECTION	
BATIMENT A																												
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																												
ZDA N°29	RDC - BATIMENT A - CIRCULATION													ZC05	SO	SO	SO	CCF01 A CCF10	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°33	ETAGE 1 - BATIMENT A - CIRCULATION													ZC12	PCFA07	SO	SO	CCF01 A CCF10 CCF13 A CCF22	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°34	ETAGE 1 - BATIMENT A - LOCAUX													ZC12	PCFA07	SO	SO	CCF01 A CCF10 CCF13 A CCF22	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°41	ETAGE 2 - BATIMENT A - CIRCULATION													ZC21	SO	PCFA18 PCFA19	SO	CCF13 A CCF22 CCF27 A CCF31 CCF33 A CCF41	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°42	ETAGE 2 - BATIMENT A - LOCAUX DIVERS													ZC21	SO	PCFA18 PCFA19	SO	CCF13 A CCF22 CCF27 A CCF31 CCF33 A CCF41	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°49	ETAGE 3 - BATIMENT A - CIRCULATION													ZC33	PCFA39 PCFA40	SO	SO	CCF27 A CCF31 CCF33 A CCF41	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°134	RDC - BATIMENT A - LOCAUX													ZC05	SO	SO	SO	CCF01 A CCF10	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																												
ZDM N°30	RDC - BATIMENT A																				ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°35	ETAGE 1 - BATIMENT A																				ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°43	ETAGE 2 - BATIMENT A																				ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°50	ETAGE 3 - BATIMENT A																				ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
BATIMENT B																												
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																												
ZDA N°62	RDC - BATIMENT B - CIRCULATION													ZC03	PCFA03	SO	SO	CCF01 A CCF04 CCF15 A CCF17	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°67	ETAGE 1 - BATIMENT B - CIRCULATION													ZC10	PCFA09	SO	SO	CCF01 A CCF03	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°71	ETAGE 2 - BATIMENT B - CIRCULATION													ZC18	PCFA18	SO	SO	CCF02 / CCF03 CCF05 A CCF08	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°77	ETAGE 3 - BATIMENT B - CIRCULATION													ZC30	PCFA28	SO	SO	CCF05 A CCF08	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°141	RDC - BATIMENT B - LOCAUX													ZC10	PCFA09	SO	SO	CCF01 A CCF03	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																												
ZDM N°61	RDC - BATIMENT B																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°66	ETAGE 1 - BATIMENT B																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°70	ETAGE 2 - BATIMENT B																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°76	ETAGE 3 - BATIMENT B																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

A2Ci. Prévention incendie. Audit, Coordination SSI, Conseil et Ingénierie en prévention incendie, AMO, Formation Incendie et 1er Secours. Parc d'Activités du pays de Langon - 15 Rue des Acacias - 33210 MAZERES Tél: 05.56.27.23.67 / Fax : 05.24.22.20.00
SAS au capital de 3 000 €. - E-mail: contact@a2ci-prevention-incendie.fr - N° SIRET 487 945 388 00030

TABEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 2 sur 7)

CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE											COMPARTIMENTAGE					EVACUATION									
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPEURE SONORISATION / PROJECTION
BATIMENT C																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°94	RDC - BATIMENT C - CIRCULATION													ZC01	PCFA05	SO	SO	CCF01	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°95	RDC - BATIMENT C - LOCAUX DIVERS													ZC01	PCFA05	SO	SO	CCF01	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°100	ETAGE 1 - BATIMENT C - CIRCULATION													ZC08	PCFA10	SO	SO	CCF01 / CCF02	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°101	ETAGE 1 - BATIMENT C - LOCAUX DIVERS													ZC08	PCFA10	SO	SO	CCF01 / CCF02	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°106	ETAGE 2 - BATIMENT C - CIRCULATION													ZC15	PCFA20	SO	SO	CCF02 CCF13 A CCF25	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°114	ETAGE 3 - BATIMENT C - CIRCULATION													ZC27	PCFA31	SO	SO	CCF13 A CCF25	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°93	RDC - BATIMENT C																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°99	ETAGE 1 - BATIMENT C																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°105	ETAGE 2 - BATIMENT C																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°113	ETAGE 3 - BATIMENT C																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
BATIMENT D																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°111	ETAGE 1 - BATIMENT D - CIRCULATION													ZC17	PCF R+1	PCFA19	CCF52	CCF34 A CCF39	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°118	ETAGE 2 - PABIM - CIRCULATION													ZC29	PCF1 / PCF4 PCF6	SO	SO	CCF01 A CCF04 CCF15 A CCF17	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°142	ETAGE 2 - PABIM - LOCAUX													ZC29	PCF1 / PCF4 PCF6	SO	SO	CCF R2-1 & CCF R2 2 CCF34 A CCF39	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°158	R+1 - LOCAUX FACE BIO IMAGERIE													ZC17	PCF R+1	PCFA19	CCF52	CCF34 A CCF39	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°110	ETAGE 1 - BATIMENT D																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°117	ETAGE 2 - BATIMENT D																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

A2Ci. Prévention incendie. Audit, Coordination SSI, Conseil et Ingénierie en prévention incendie, AMO, Formation Incendie et 1er Secours. Parc d'Activités du pays de L'Anjou - 15 Rue des Acacias - 33210 MAZERES Tél: 05.56.27.23.67 / Fax : 05.24.22.20.00
SAS au capital de 3 000 €. - E-mail: contact@a2ci-prevention-incendie.fr - N° SIRET 487 945 388 00030

TABEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 3 sur 7)

CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE											COMPARTIMENTAGE					EVACUATION									
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CIA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPURE SONORISATION / PROJECTION
BATIMENT E																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°97	SOUS-SOL - BATIMENT E - CIRCULATION													ZC02	PCFA04	SO	SO	SO	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°98	SOUS-SOL - BATIMENT E - LOCAUX DIVERS													ZC02	PCFA04	SO	SO	SO	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°103	RDC - BATIMENT E - CIRCULATION													ZC09	PCFA33 PCFA34	SO	SO	CCF04 / CCF06 CCF07 CCF09 A CCF12	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°104	RDC - BATIMENT E - LOCAUX DIVERS													ZC09	PCFA33 PCFA34	SO	SO	CCF04 / CCF06 CCF07 CCF09 A CCF12	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°108	ETAGE 1 - BATIMENT E - CIRCULATION													ZC16	PCFA37 PCFA38	SO	SO	CCF04 / CCF06 CCF07 CCF09 A CCF12 CCF26 A CCF33	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°109	ETAGE 1 - BATIMENT E ET D - LOCAUX DIVERS													ZC17	PCF R+1	PCFA19	CCF52	CCF34 A CCF39	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°112	ETAGE 1 - BATIMENT E - LOCAUX DIVERS													ZC16	PCFA37 PCFA38	SO	SO	CCF04 / CCF06 CCF07 CCF09 A CCF12 CCF26 A CCF33	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°116	ETAGE 2 - BATIMENT E - CIRCULATION													ZC28	PCFA30	SO	SO	CCF26 A CCF33 CCF41 A CCF44 CCF47 A CCF50	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°120	ETAGE 3 - BATIMENT E - CIRCULATION																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°122	BATIMENT E - MACHINERIE ASCENSEUR NORD																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°123	BATIMENT E - MACHINERIE ASCENSEUR SUD																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDA N°140	ETAGE 3 - BATIMENT E - CIRCULATION													ZC39	PCFA34	SO	SO	CCF41 A CCF44 CCF47 A CCF50	X	ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°96	SOUS-SOL - BATIMENT E																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°102	RDC - BATIMENT E																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°107	ETAGE 1 - BATIMENT E																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°115	ETAGE 2 - BATIMENT E																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°119	ETAGE 3 - BATIMENT E																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°121	BATIMENT E - MACHINERIE ASCENSEUR NORD																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO
ZDM N°133	ETAGE 3 - BATIMENT E																			ZA04	X	ISPCFC06, ISPCF10 A ISPCF12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCF1 A DVISPCF4, DVISPCF6	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

A2Ci, Prévention incendie. Audit, Coordination SSI, Conseil et Ingénierie en prévention incendie, AMO, Formation Incendie et 1er Secours, Parc d'Activités du pays de L'aron - 15 Rue des Acacias - 33210 MAZERES Tel: 05.56.27.23.67 / Fax : 05.24.22.20.00
SAS au capital de 3 000 €. - E-mail: contact@a2ci-prevention-incendie.fr - N° SIRET 487 945 388 00030

TABEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 4 sur 7)
CHANTIER: Université de Bordeaux - Bâtiment CAREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE											COMPARTIMENTAGE					EVACUATION										
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFFLEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRÊT TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRÊT TECHNIQUE NON-ARRÊT ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRÊT TECHNIQUE COUPURE SONORISATION / PROJECTION	
BATIMENT F																												
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																												
ZDA N°75	ETAGE 1 - BATIMENT F - CIRCULATION													ZC20	SO	PCFA18 PCFA19 1PCF R+1	SO	SO	SO	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°168	ETAGE 1 - BATIMENT F - LOCAUX DIVERS													ZC20	SO	PCFA18 PCFA19 1PCF R+1	SO	SO	SO	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°81	ETAGE 2 - BATIMENT F - CIRCULATION													ZC32	SO	PCF26	SO	SO	SO	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																												
ZDM N°74	ETAGE 1 - BATIMENT F																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°80	ETAGE 2 - BATIMENT F - CIRCULATION																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
BATIMENT G																												
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																												
ZDA N°64	SOUS-SOL - BATIMENT G - CIRCULATION													ZC04	PCFA02	SO	SO	SO	SO	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°65	SOUS-SOL - BATIMENT G - LOCAUX DIVERS													ZC04	PCFA02	SO	SO	SO	SO	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°69	RDC - BATIMENT G - CIRCULATION													ZC11	PCFA08	SO	SO	CCF04	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°73	ETAGE 1 - BATIMENT G - CIRCULATION													ZC19	PCFA17	SO	SO	CCF04 CCF09 / 09BIS CCF10 / 10BIS	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°79	ETAGE 2 - BATIMENT G - CIRCULATION													ZC31	PCFA27	SO	SO	CCF09 / 09BIS CCF10 / 10BIS CCF11 A CCF16	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
ZDA N°83	ETAGE 3- BATIMENT G - CIRCULATION																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°85	BATIMENT G - MACHINERIE ASCENSEUR NORD																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°86	BATIMENT G - MACHINERIE ASCENSEUR SUD																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDA N°139	ETAGE 3 - BATIMENT G - CIRCULATION													ZC41	PCFA32	SO	SO	CCF53 A CCF60 CCF63 A CCF66	X	ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
BATIMENT G																												
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																												
ZDM N°63	SOUS-SOL - BATIMENT G																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°68	RDC - BATIMENT G																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°72	ETAGE 1 - BATIMENT G																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°78	ETAGE 2 - BATIMENT G																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°82	ETAGE 3 - BATIMENT G																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°84	BATIMENT G - MACHINERIE ASCENSEUR NORD																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
ZDM N°132	ETAGE 3 - BATIMENT G																				ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO
BATIMENT H																												
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																												
ZDA N°36	ETAGE 1 - BATIMENT H - CIRCULATION													ZC23	SO	PCFA14 PCFA18	SO	CCF49 A CCF52	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
ZDA N°44	ETAGE 2 - BATIMENT H - CIRCULATION													ZC35	SO	PCFA24 PCFA26	SO	CCF49 A CCF52	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
BATIMENT H																												
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																												
ZDM N°37	ETAGE 1 - BATIMENT H - CIRCULATION																				ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°45	ETAGE 2 - BATIMENT H - CIRCULATION																				ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

TABLEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 5 sur 7)
CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE											COMPARTIMENTAGE					EVACUATION									
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPEURE SONORISATION / PROJECTION
BATIMENT I																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°31	RDC - BATIMENT I - CIRCULATION												ZC13	SO	SO	SO		CCF11 / CCF12 CCF23 A CCF26	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°38	ETAGE 1 - BATIMENT I - CIRCULATION												ZC22	PCFA15	SO	SO		CCF23 A CCF26 CCF42 A CCF48	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°39	ETAGE 1 - BATIMENT I - LOCAUX DIVERS												ZC22	PCFA15	SO	SO		CCF23 A CCF26 CCF42 A CCF48	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°46	ETAGE 2 - BATIMENT I - CIRCULATION												ZC34	PCFA25	SO	SO		CCF42 A CCF48 CCF53 A CCF60 CCF63 A CCF66	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°47	ETAGE 2 - BATIMENT I - LOCAUX DIVERS												ZC34	PCFA25	SO	SO		CCF42 A CCF48 CCF53 A CCF60 CCF63 A CCF66	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°51	ETAGE 3 - BATIMENT I - CIRCULATION																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°53	BATIMENT I - MACHINERIE ASCENSEUR NORD																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°55	BATIMENT I - MACHINERIE ASCENSEUR SUD																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°127	SOUS-SOL - BATIMENT I - LOCAUX TECHNIQUES												ZC06	SO	SO	SO		CCF11 / CCF12	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°128	SOUS-SOL - BATIMENT I - CIRCULATION												ZC06	SO	SO	SO		CCF11 / CCF12	X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°129	SOUS-SOL - BATIMENT I - PLENUM CIRCULATION																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°136	ETAGE 3 - BATIMENT I - LOCAUX																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDA N°138	ETAGE 3 - BATIMENT I - CIRCULATION												ZC43	X		X	SO		X	ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°28	SOL-SOL - BATIMENT I																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°32	RDC - BATIMENT I																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°40	ETAGE 1 - BATIMENT I																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°48	ETAGE 2 - BATIMENT I																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°52	ETAGE 3 - BATIMENT I																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°54	BATIMENT I - MACHINERIE ASCENSEUR NORD																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO
ZDM N°131	ETAGE 3 - BATIMENT I																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCF23, ISPCF15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

TABLEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 6 sur 7)
CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE											COMPARTIMENTAGE						EVACUATION								
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPEURE SONORISATION / PROJECTION
BATIMENT J																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°07	ETAGE 1 - BATIMENT J - CIRCULATION													ZC25	PCFA12	PCFA11	SO	CCF06 A CCF14	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°08	ETAGE 1 - BATIMENT J - LOCAUX DIVERS													ZC25	PCFA12	PCFA11	SO	CCF06 A CCF14	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°15	ETAGE 2 - BATIMENT J - CIRCULATION													ZC37	PCFA27	PCFA21, PCFA24	SO	CCF06 CCF08 A CCF14	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°09	ETAGE 1 - BATIMENT J																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°16	ETAGE 2 - BATIMENT J - CIRCULATION																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
BATIMENT K																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°01	RDC - BATIMENT K - LOCAUX													ZC14	PCFA13	SO	SO	SO	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°02	SOUS-SOL - BATIMENT K - CIRCULATION													ZC07	PCFA13	SO	SO	SO	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°03	SOUS-SOL - BATIMENT K - LOCAUX DIVERS													ZC07	PCFA13	SO	SO	SO	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°05	RDC - BATIMENT K - CIRCULATION													ZC14	PCFA13	SO	SO	SO	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°10	ETAGE 1 - BATIMENT K - CIRCULATION													ZC24	PCFA13	SO	SO	CCF01 A CCF04	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°11	ETAGE 1 - BATIMENT K - LOCAUX DIVERS													ZC24	PCFA13	SO	SO	CCF01 A CCF04	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°17	ETAGE 2 - BATIMENT K - CIRCULATION													ZC36	PCFA23	SO	SO	CCF01 A CCF04 CCF15 A CCF17	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°22	ETAGE 3 - BATIMENT K - CIRCULATION																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°24	BATIMENT K -MACHINERIE ASCENSEUR NORD																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°26	BATIMENT K -MACHINERIE ASCENSEUR SUD																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°137	ETAGE 3 - BATIMENT K - CIRCULATION													ZC45	SO	SO	SO	SO	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°04	SOUS-SOL - BATIMENT K																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°06	RDC - BATIMENT K																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°12	ETAGE 1 - BATIMENT K																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°18	ETAGE 2 - BATIMENT K																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°23	ETAGE 3 - BATIMENT K																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°25	BATIMENT K -MACHINERIE ASCENSEUR NORD																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°130	ETAGE 3 - BATIMENT K																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
BATIMENT L																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°13	ETAGE 1 - BATIMENT L - CIRCULATION													ZC26	SO	PCFA11	SO	CCF05	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°19	ETAGE 2 - BATIMENT L - CIRCULATION													ZC38	SO	PCFA21	SO	CCF05	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDA N°20	ETAGE 2 - BATIMENT L - LOCAUX													ZC38	SO	PCFA21	SO	CCF05	X	ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°14	ETAGE 1 - BATIMENT L																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO
ZDM N°21	ETAGE 2 - BATIMENT L																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

TABEAU DE CORRELATION EN MODE AUTOMATIQUE PAR LE SSI - (Page 7 sur 7)

CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° ZDA/ZDM	LIBELLE DE ZDA/ZDM	DESENFUMAGE												COMPARTIMENTAGE						EVACUATION							
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET CO²	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPURE SONORISATION / PROJECTION
BATIMENT BIO																											
ZONE DE DETECTION AUTOMATIQUE - "ZDA" -																											
ZDA N°151	SOUS-SOL - BIO IMAGERIE - CIRCULATION	ZF01	VH05	VH01 A VH03 VH04.1 / VH04.2 VH06 / VH07	VB02 / VB03 VB08	VB01 / VB04 VB05 / VB06	VB07	SO	SO	E1 A E4 ESPV / E6 E7	SO	ZF02 ZF03 ZF04	X	ZC50	PDA501 A PDA505	SO	CCF 5-SOL-1 A CCF 5-SOL-14	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°153	RDC - BIO IMAGERIE - CIRCULATION	ZF02	VH03	VH01 / VH02 VH04 A VH06	SO	VB04 / VB05	VB01 / VB03 VB06	SO	Porte Auto	E2 A E4 ESPV / E6 E7	SO	ZF01 ZF03 ZF04	X	ZC51	PDA501 A PDA504	SO	CCF RDC-1 A 7 & CCF RDC-15 A 17	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°154	RDC - BIO IMAGERIE - CIRCULATION ATRIUM													ZC51	PDA501 A PDA504	SO	CCF RDC-1 A 7 & CCF RDC-15 A 17	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°155	RDC - BIO IMAGERIE - LOCALUX ATRIUM													ZC51	PDA501 A PDA504	SO	CCF RDC-1 A 7 & CCF RDC-15 A 17	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°157	R+1 - BIO IMAGERIE - CIRCULATION	ZF03	SO	VH01 A VH04	SO	VB03 / VB04	VB01 / VB02 VB02.1 / VB05 VB05.1 / VB06	SO	SO	E1 / ESCV E6 / E7	SO	ZF01 ZF02 ZF04	X	ZC52	PDA501 PDA502	SO	CCF R1-1 & CCF R1-2	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°159	R+1 - BIO IMAGERIE - LOCALUX ATRIUM													ZC52	PDA501 PDA502	SO	CCF R1-1 & CCF R1-2	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°161	R+2 - BIO IMAGERIE - CIRCULATION	ZF04	SO	VH01 A VH03 VH05	SO	VB03 / VB04	VB01 / VB02 VB05 / VB06	SO	SO	E1 / ESCV E6 / E7	SO	ZF01 ZF02 ZF03	X	ZC53	PDA501 PDA502	SO	CCF R2-1 A CCF R2-10	CCF R2-1 & CCF R2-2	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°163	R+2 - BIO IMAGERIE - LOCALUX ATRIUM													ZC53	PDA501 PDA502	SO	CCF R2-1 A CCF R2-10	CCF R2-1 & CCF R2-2	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°164	SOUS-SOL - BIO IMAGERIE - LOCALUX													ZC50	PDA501 A PDA505	SO	CCF 5-SOL-1 A 14	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°165	RDC - BIO IMAGERIE - LOCALUX													ZC51	PDA501 A PDA504	SO	CCF RDC-1 A 7 & CCF RDC-15 A 17	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°166	R+2 - BIO IMAGERIE - LOCALUX													ZC53	PDA501 PDA502	SO	CCF R2-1 A CCF R2-10	CCF R2-1 & CCF R2-2	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDA N°167	SOUS-SOL - BIO IMAGERIE - LOCALUX													ZC50	PDA501 A PDA505	SO	CCF 5-SOL-1 A 14	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZONE DE DECLENCHEUR MANUEL - "ZDM" -																											
ZDM N°150	SOUS-SOL - BIO IMAGERIE													ZC50	PDA501 A PDA505	SO	CCF 5-SOL-1 A 14	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDM N°152	RDC - BIO IMAGERIE - CIRCULATION													ZC51	PDA501 A PDA504	SO	CCF RDC-1 A 7 & CCF RDC-15 A 17	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDM N°156	R+1 - BIO IMAGERIE - CIRCULATION													ZC52	PDA501 PDA502	SO	CCF R1-1 & CCF R1-2	SO	X	ZA05	X	X	SO	SO	SO	SO	SO
ZDM N°160	R+2 - BIO IMAGERIE - CIRCULATION													ZC53	PDA501 PDA502	SO	CCF R2-1 A CCF R2-10	CCF R2-1 & CCF R2-2	X	ZA05	X	X	SO	SO	SO	SO	SO

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

TABLEAU DE CORRELATION EN MODE MANUEL PAR LE SSI - (Page 1 sur 2)

CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° UCMC	LIBELLE DE LA FONCTION	DESENFUMAGE											COMPARTIMENTAGE						EVACUATION									
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	DAC COFFRET C04	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPEUR SONORISATION / PROJECTION	
N° 01	COMPARTIMENTAGE - RDC - BATIMENT C / 1B - "ZC01"													ZC01	PCFA05	SO	SO	CCF01	X									
N° 02	COMPARTIMENTAGE - S/SOL - BATIMENT E / 1A - "ZC02"													ZC02	PCFA04	SO	SO	CCF09 / 09BIS CCF10 / 10BIS CCF11 A CCF16	X									
N° 03	COMPARTIMENTAGE - RDC - BATIMENT B / 2B - "ZC03"													ZC03	PCFA03	SO	SO	CCF01	X									
N° 04	COMPARTIMENTAGE - SOLUS-SOL - BATIMENT G / 2A - "ZC04"													ZC04	PCFA39 PCFA40	SO	SO	SO	X									
N° 05	COMPARTIMENTAGE - RDC - BATIMENT A / 3B - "ZC05"													ZC05	SO	SO	SO	CCF01 A CCF10	X									
N° 06	COMPARTIMENTAGE - SOLUS-SOL - BATIMENT I / 3A - "ZC06"													ZC06	SO	PCFA24 PCFA26	SO	CCF11 / CCF12	X									
N° 07	COMPARTIMENTAGE - SOLUS-SOL - BATIMENT K / 4A - "ZC07"													ZC07	PCFA13	SO	SO	SO	X									
N° 08	COMPARTIMENTAGE - R+1 - BATIMENT C / 1B - "ZC08"													ZC08	PCFA10	PCFA21 PCFA24	SO	CCF01 / CCF02	X									
N° 09	COMPARTIMENTAGE - RDC - BATIMENT E / 1A - "ZC09"													ZC09	PCFA33 PCFA34	SO	SO	CCF04 / CCF06 CCF07 CCF09 A CCF12	X									
N° 10	COMPARTIMENTAGE - R+1 - BATIMENT B / 2B- "ZC10"													ZC10	PCFA09	SO	SO	CCF01 A CCF03	X									
N° 11	COMPARTIMENTAGE - RDC - BATIMENT G / 2A - "ZC11"													ZC11	PCFA08	SO	SO	CCF04	X									
N° 12	COMPARTIMENTAGE - R+1 - BATIMENT A / 3B - "ZC12"													ZC12	PCFA07	SO	SO	CCF01 A CCF10 CCF13 A CCF22	X									
N° 13	COMPARTIMENTAGE - RDC - BATIMENT I / 3A - "ZC13"													ZC13	SO	SO	SO	CCF11 / CCF12 CCF23 A CCF26	X									
N° 14	COMPARTIMENTAGE - RDC - BATIMENT K / 4A - "ZC14"													ZC14	PCFA13	SO	SO	SO	X									
N° 15	COMPARTIMENTAGE - R+2 - BATIMENT C / 1B - "ZC15"													ZC15	PCFA20	SO	SO	CCF02 CCF13 A CCF25	X									
N° 16	COMPARTIMENTAGE - R+1 - BATIMENT E / 1A - "ZC16"													ZC16	PCFA37 PCFA38	SO	SO	CCF04 / CCF06 CCF07 CCF09 A CCF12 CCF26 A CCF33	X									
N° 17	COMPARTIMENTAGE - R+1 - BATIMENT D / 1A - "ZC17"													ZC17	PCF R+1	PCFA19	CCF52	CCF34 A CCF39	X									
N° 18	COMPARTIMENTAGE - R+2 - BATIMENT B / 2B - "ZC18"													ZC18	PCFA18	SO	SO	CCF02 / CCF03 CCF05 A CCF08	X									
N° 19	COMPARTIMENTAGE - R+1 - BATIMENT G / 2A - "ZC19"													ZC19	PCFA17	SO	SO	CCF04 CCF09 / 09BIS CCF10 / 10BIS	X									
N° 20	COMPARTIMENTAGE - R+1 - BATIMENT F / 2A - "ZC20"													ZC20	SO	PCFA18 PCFA19 1PCF R+1	SO	SO	X									
N° 21	COMPARTIMENTAGE - R+2 - BATIMENT A / 3B - "ZC21"													ZC21	SO	PCFA18 PCFA19	SO	CCF13 A CCF22 CCF27 A CCF31 CCF33 A CCF41	X									
N° 22	COMPARTIMENTAGE - R+1 - BATIMENT I / 3A - "ZC22"													ZC22	PCFA15	SO	SO	CCF23 A CCF26 CCF42 A CCF48	X									
N° 23	COMPARTIMENTAGE - R+1 - BATIMENT H / 3A - "ZC23"													ZC23	SO	PCFA14 PCFA18	SO	CCF49 A CCF52	X									
N° 24	COMPARTIMENTAGE - R+1 - BATIMENT K / 4A - "ZC24"													ZC24	PCFA13	SO	SO	CCF01 A CCF04	X									
N° 25	COMPARTIMENTAGE - R+1 - BATIMENT J / 4A - "ZC25"													ZC25	PCFA12	PCFA11	SO	CCF06 A CCF14	X									
N° 26	COMPARTIMENTAGE - R+1 - BATIMENT L / 4A - "ZC26"													ZC26	SO	PCFA11	SO	CCF05	X									
N° 27	COMPARTIMENTAGE - R+3 - BATIMENT C / 1B - "ZC27"													ZC27	PCFA31	SO	SO	CCF13 A CCF25	X									
N° 28	COMPARTIMENTAGE - R+2 - BATIMENT E / 1A - "ZC28"													ZC28	PCFA30	SO	SO	CCF26 A CCF33 CCF41 A CCF44 CCF47 A CCF50	X									
N° 29	COMPARTIMENTAGE - R+2 - BATIMENT D / 1A - "ZC29"													ZC29	PCF1 PCF4 PCF6	SO	SO	CCF R2-1 & CCF R2 2 CCF34 A CCF39	X									
N° 30	COMPARTIMENTAGE - R+3 - BATIMENT B / 2B - "ZC30"													ZC30	PCFA28	SO	SO	CCF05 A CCF08	X									

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.

TABLEAU DE CORRELATION EN MODE MANUEL PAR LE SSI - (Page 2 sur 2)
CHANTIER: Université de Bordeaux - Bâtiment CARREIRE - 351 Cours de la libération - 33400 TALENCE

N° UCMC	LIBELLE DE LA FONCTION	DESENFUMAGE												COMPARTIMENTAGE						EVACUATION								
		N° ZF	VCF VH N°	VCF DAS COMMUN VH N°	VCF VB N°	VCF DAS COMMUN VB N°	OUVRANT DE FACADE	EXUTOIRE EN TOITURE	OUVERTURE PORTE AUTOMATIQUE	N° COFFRET DE RELAYAGE EXTRACTEUR	N° COFFRET DE RELAYAGE INSUFFLEATEUR	INTERVERROUILLAGE AUTOMATIQUE	ARRET TECHNIQUE - CTA - VENTILATION	N° ZC	N° DAS PCF RECOUPEMENT CIRCULATION ET ESCALIER	N° DAS PCF COMMUN	N° DAS CCF	N° DAS CCF COMMUN	ARRET TECHNIQUE NON-ARRET ASC (NIVEAU)	N° ZA	ALARME GENERALE AG	DEVERROUILLAGE ISSUES DE SECOURS	ECLAIRAGE DE SECURITE	DIFFUSEUR LUMINEUX	REMISE EN LUMIERE	PANNEAU ENTREE INTERDITE	ARRET TECHNIQUE COUPEURE SONORISATION / PROJECTION	
N° 31	COMPARTIMENTAGE - R+2 - BATIMENT G / 2A - "ZC31"													ZC31	PCFA27	SO	SO	CCF09 / 09BIS CCF10 / 10BIS CCF11 A CCF16	X									
N° 32	COMPARTIMENTAGE - R+2 - BATIMENT F / 2A - "ZC32"													ZC32	SO	PCF26	SO	SO	SO	X								
N° 33	COMPARTIMENTAGE - R+3 - BATIMENT A / 3B - "ZC33"													ZC33	PCFA39 PCFA40	SO	SO	CCF27 A CCF31, CCF33 A CCF41	X									
N° 34	COMPARTIMENTAGE - R+2 - BATIMENT I / 3A - "ZC34"													ZC34	PCFA25	SO	SO	CCF42 A CCF48, CCF53 A CCF60, CCF63 A CCF66	X									
N° 35	COMPARTIMENTAGE - R+2 - BATIMENT H / 3A - "ZC35"													ZC35	SO	PCFA24 PCFA26	SO	CCF49 A CCF52	X									
N° 36	COMPARTIMENTAGE - R+2 - BATIMENT K / 4A - "ZC36"													ZC36	PCFA23	SO	SO	CCF01 A CCF04, CCF15 A CCF17	X									
N° 37	COMPARTIMENTAGE - R+2 - BATIMENT J / 4A - "ZC37"													ZC37	PCFA27	PCFA21 PCFA24	SO	CCF06, CCF08 A CCF14	X									
N° 38	COMPARTIMENTAGE - R+2 - BATIMENT L / 4A - "ZC38"													ZC38	SO	PCFA21	SO	CCF05	X									
N° 39	COMPARTIMENTAGE - R+3 - BATIMENT E / 1A - "ZC39"													ZC39	PCFA34	SO	SO	CCF41 A CCF44, CCF47 A CCF50	X									
N° 40	COMPARTIMENTAGE - R+3 - BATIMENT G / 1A - "ZC40"													ZC40	PCFA33	SO	SO	CCF11 A CCF16	X									
N° 41	COMPARTIMENTAGE - R+3 - BATIMENT I / 2A - "ZC41"													ZC41	PCFA32	SO	SO	CCF53 A CCF60, CCF63 A CCF66	X									
N° 42	COMPARTIMENTAGE - R+3 - BATIMENT K / 2A - "ZC42"													ZC42	SO	SO	SO	CCF15 A CCF17	X									
N° 43	COMPARTIMENTAGE - R+3 - BATIMENT 3A - "ZC43"													ZC43	X		X	SO	X									
N° 44	COMPARTIMENTAGE - R+3 - BATIMENT 3A - "ZC44"													ZC44	X		X	SO	X									
N° 45	COMPARTIMENTAGE - R+3 - BATIMENT 4A - "ZC45"													ZC45	SO	SO	SO	SO	X									
N° 46	COMPARTIMENTAGE - R+3 - BATIMENT 4A - "ZC46"													ZC46	SO		X	SO	X									
N° 50	COMPARTIMENTAGE - SOLUS-SOL - BATIMENT BIO/IMN - "ZC50"													ZC50	PDA501 A PDA505	SO	CCF S-SOL-1 A CCF S-SOL-14	SO	X									
N° 51	COMPARTIMENTAGE - RDC - BATIMENT BIO/IMN - "ZC51"													ZC51	PDA501 A PDA504	SO	CCF RDC-1 A 7 & CCF RDC-15 A CCF RDC-17	SO	X									
N° 52	COMPARTIMENTAGE - R+1 - BATIMENT BIO/IMN - "ZC52"													ZC52	PDA501 PDA502	SO	CCF R1-1 & CCF R1-2	SO	X									
N° 53	COMPARTIMENTAGE - R+2 - BATIMENT BIO/IMN - "ZC53"													ZC53	PDA501 PDA502	SO	CCF R2-1 A CCF R2-10	CCF R2-1 & CCF R2-2	X									
N° 55	DESENFUMAGE - SOLUS-SOL - BATIMENT BION / IMN - COULOIR - "ZF01"	ZF01	VH05	VH01 A VH03 VH04.1 / VH04.2 VH06 / VH07	VB02 / VB03 VB08	VB01 / VB04 VB05 / VB06	VB07	SO	SO	E1 A E4 ESPV / E6 E7	SO	ZF02 ZF03 ZF04	X															
N° 56	DESENFUMAGE - RDC - BATIMENT BION / IMN - COULOIR - "ZF02"	ZF02	VH03	VH01 / VH02 VH04 A VH06	SO	VB04 / VB05	VB01 / VB03 VB06	SO	Porte Auto	E2 A E4 ESPV / E6 E7	SO	ZF01 ZF03 ZF04	X															
N° 57	DESENFUMAGE - R+1 - BATIMENT BION / IMN - COULOIR - "ZF03"	ZF03	SO	VH01 A VH04	SO	VB03 / VB04	VB01 / VB02 VB02.1 / VB05 VB05.1 / VB06	SO	SO	E1 / ESGV E6 / E7	SO	ZF01 ZF02 ZF04	X															
N° 58	DESENFUMAGE - R+2 - BATIMENT BION / IMN - COULOIR - "ZF04"	ZF04	SO	VH01 A VH03 VH05	SO	VB03 / VB04	VB01 / VB02 VB05 / VB06	SO	SO	E1 / ESGV E6 / E7	SO	ZF01 ZF02 ZF03	X															
UGA 01	EVACUATION GENERALE BATIMENTS J / K / L																			ZA01	X	ISPCFC13, ISPCFC14, ISPCFC32	SO	SO	SO	SO	SO	
UGA 02	EVACUATION GENERALE BATIMENTS A / I / H																			ZA02	X	ISPCFC01, ISPCFC07, ISPCFC8, ISPCF802, ISPCFC03, ISPCFC30, ISPCFC31, ISPCFC21 A ISPCFC23, ISPCFC15, ISPCFC17, ISPCFC18	SO	SO	SO	SO	SO	
UGA 03	EVACUATION GENERALE BATIMENTS B / G / F																			ZA03	X	ISPCFC03, ISPCFC25, ISPCFC27, ISPCFC28, PCF1 R+2, PCF2 R+2	SO	SO	SO	SO	SO	
UGA 04	EVACUATION GENERALE BATIMENTS C / D / E																			ZA04	X	ISPCFC06, ISPCFC10 A ISPCFC12, ISPCFC19, ISPCFC20 R+1, ISPCFC20 R+2, ISPCFC29, ISPCFC28, DVISPCFC1 A DVISPCFC4, DVISPCFC6	SO	SO	SO	SO	SO	
UGA 05	EVACUATION GENERALE BATIMENT BIO IMAGINERIE																			ZA05	X	X	SO	SO	SO	SO	SO	

TABLEAU DE CORRELATION EN MODE MANUEL NON ASSERVI AU SSI																									
ZF01 - DESENFUMAGE ESCALIER 1										ZF ESC1 Commande manuelle par un coffret DCM situé dans la cage d'escalier															
ZF02 - DESENFUMAGE ESCALIER 2										ZF ESC2 Commande manuelle par un coffret DCM situé dans la cage d'escalier															

NOTA: les colonnes non renseignées = Pas d'équipements prévus au stade de conception du cahier des charges fonctionnel.