

## Declaration of Incorporation of Partly Completed Machinery

**Description of the delivery:** Centrifugal pump(s).

Project number	Pump serial number	Pump type	Item-/ Tag number
4140961	57942 (single shaft end)	Venus1-300.410	10
4140961	57943 (double shaft end)	Venus1-300.410	20

**Applicable directive:** Machinery Directive 2006/42/EC

**Applicable standards:**

EN-ISO 12100 (2010) Safety of machinery - General principles for design - risk assessment and risk reduction.

EN 809 (1998 + A1: 2009 and C1:2010) Pumps and pump units for liquids.

Common safety requirements.

EN 60204-1 (2006 + A1: 2009 and C11:2010) Safety of machinery. Electrical equipment of machinery. Part 1: General requirements.

**Declaration:**


We, Nijhuis Pompen B.V., declare under our sole responsibility, that the fore mentioned pump(s) is (are) in compliance with the mentioned standards, article 13 and the following paragraphs of appendix 1 of the Machinery Directive. Paragraphs 1.1.2, 1.1.3, 1.1.5, 1.3.1, 1.3.2, 1.3.4, 1.3.6, 1.3.7 (not for the shaft coupling), 1.3.8, 1.4.1, 1.4.2.1 (for remaining risks see operation manual), 1.5.2, 1.5.3, 1.5.4, 1.5.6, 1.5.8, 1.5.9, 1.6.1, 1.6.2, 1.7.3 (there is no CE marking on the pump) and 1.7.4.

It is not allowed to put into operation the fore mentioned pump(s) prior to the assembled unit in which the pumps are to operate, have been declared in conformity with the applicable provisions of the Machinery Directive as well as any additional and applicable directive or requirements. Please note that in particular both the shaft coupling with its driving machine and the coupling guard are not incorporated in the risk assessment.

In accordance with this declaration and the Machinery Directive, Nijhuis Pompen B.V. would submit relevant information (data) on the fore mentioned pump(s), if a motivated request from a national authority was received.

The information will be supplied digitally (pdf files) or as hard copies.

Signed in Winterswijk (Netherlands) on 9-12-2014,



i.a.w. H.W.J. Bos,  
Quality Manager