













PLAN NIVEAU R+2

The floor plan for Level R+2 is a complex layout with numerous rooms and functional areas. Key features include:


- Central Circulation:** A large central area with multiple stairwells and elevators, labeled "Circulation".
- Workstations:** Numerous desks and workstations are distributed throughout the plan, many labeled "F2".
- Meeting Rooms:** Several rooms are designated for meetings, including "Salle de réunion" and "Représentation".
- Kitchen Area:** Located on the right side, it includes "Espace frigos (x 3 U) et fours micro-ondes (x 3U) : environ 15 PC", "Eviers simples x 2 U", and a "Fontaine à eau".
- Storage and Logistics:** Areas for "Stock consommables", "Archives", and "Bureau 160x80" are shown.
- Infrastructure:** The plan includes various technical elements such as "Local serveur + onduleur", "Imprimante", "Climatiseur", and "Goulotte".
- Other Rooms:** "Managers Control", "CPAP", "CRA/IDIRA 2P", "CRA/IDIRA 1P", "CRA/IDIRA 8P", "Salle de repos", "Espace convivialité", and "Salle de conférence" are also present.

Color-coded lines and boxes highlight specific areas and equipment:

- TGBT SG1:** A pink line and box highlighting a specific area in the central circulation and meeting rooms.
- TGBT SG2:** An orange line and box highlighting a specific area in the kitchen and reception area.
- TD R+2:** A green line and box highlighting a specific area in the central circulation and meeting rooms.

SYMBÔLE	TYPE	DESIGNATION	HT	DIMEN
	SS1	Centrale d'alarme incendie type 1 (câblage fourniture et pose)		
	TR1	Tableau de report (câblage fourniture et pose)		150cm
	DR1	Déclencheur manuel adressable (câblage fourniture et pose)		110cm
	SI1	Difuséur sonore (câblage fourniture et pose)	SS:FX	
	FI1	Difuséur lumineux (câblage fourniture et pose)	SS:FX:P	
	DO1	Déclencheur optique adressable (câblage fourniture et pose)		
	IS	Indicateur d'alarme incendie (câblage fourniture et pose)		
	DAS	PORTE DAS		
		Cable 1p 810ème SYT C2		
		Cable 2x1 5 CR1-C1		
		Cable 1p 810ème CR1-C1		
		Cable 3G1 5 CR1-C1		

[illegible]

<h1>PLAN D'IMPLANTATION DES EQUIPEMENTS ELECTRIQUES</h1> <h2>NIVEAU R+2</h2>	PHASE :
	EXE
	Numéro de plan :
	EL04
 <p>DEGREANE <i>ELEC</i></p> <p>125 avenue Louis Bréguet ZAC GAVARRY 80501 LA CRAU Tél. 04 38 01 25 26 Fax 04 38 01 23 00</p>	Indice :
	I
	Echelle :
	1 / 50°