

				Saison 2021 30/09/21 -> 10/05/22			Saison 2022 21/09/22 -> 09/05/23			Saison 2023 21/09/23 -> 22/05/24		
	Nom du site	Combustible	Energie	Conso NC	DJU	NC/DJU	Conso NC	DJU	NC/DJU	Conso NC	DJU	NC/DJU
Montbéliard	<b>Sous Station 54</b>	<b>RCU</b>	UTILE									
Montbéliard	STGI A	RCU	UTILE	267 878	2 531	<b>105,84</b>	208 204	2 341	<b>88,94</b>	187 732	2 290	<b>81,98</b>
Montbéliard	STGI B + amphithéâtre du bâtiment B	RCU	UTILE	254 948	2 531	<b>100,73</b>	198 154	2 341	<b>84,65</b>	178 670	2 290	<b>78,02</b>
Montbéliard	STGI C	RCU	UTILE	229 379	2 531	<b>90,63</b>	178 281	2 341	<b>76,16</b>	160 752	2 290	<b>70,20</b>
Montbéliard	Amphithéâtre	RCU	UTILE	113 545	2 531	<b>44,86</b>	88 251	2 341	<b>37,70</b>	79 574	2 290	<b>34,75</b>
Belfort	Louis Neel	gn T3	PCS	647 970	2 531	<b>256,01</b>	453 843	2 341	<b>193,87</b>	319 120	2 290	<b>139,35</b>
Belfort	Léon Delarbre	gn T2	PCS	327 649	2 531	<b>129,45</b>	286 335	2 341	<b>122,31</b>	322 204	2 290	<b>140,70</b>
Belfort	Bâtiment Energie 1	gn T2	PCS	213 929	2 531	<b>84,52</b>	82 261	2 341	<b>35,14</b>	97 858	2 290	<b>42,73</b>
Belfort	Bâtiment Energie 2	gn T2	PCS	132 743	2 531	<b>52,45</b>	170 153	2 341	<b>72,68</b>	138 064	2 290	<b>60,29</b>
Montbéliard	Laboratoire	RCU	UTILE	172 819	2 531	<b>68,28</b>	134 321	2 341	<b>57,38</b>	121 114	2 290	<b>52,89</b>
Montbéliard	BU Montbéliard	RCU	UTILE	204 975	2 531	<b>80,99</b>	159 314	2 341	<b>68,05</b>	143 649	2 290	<b>62,73</b>
Montbéliard	Mesures Physiques	RCU	UTILE	353 209	2 531	<b>139,55</b>	274 525	2 341	<b>117,27</b>	247 533	2 290	<b>108,09</b>
Montbéliard	MMI	RCU	UTILE	239 247	2 531	<b>94,53</b>	185 951	2 341	<b>79,43</b>	167 667	2 290	<b>73,22</b>
Montbéliard	SRC	RCU	UTILE	245 260	2 531	<b>96,90</b>	348 968	2 341	<b>149,07</b>	111 102	2 290	<b>48,52</b>
Montbéliard	GACO	RCU	UTILE	153 376	2 531	<b>60,60</b>	132 000	2 341	<b>56,39</b>	121 313	2 290	<b>52,98</b>
Belfort	<b>Eco Campus chaudiere centrale GAZ / BOIS</b>	<b>gn T3</b>	PCS	<b>2 396 541</b>	<b>2 531</b>	<b>946,88</b>	<b>2 115 577</b>	<b>2 341</b>	<b>903,71</b>	<b>2 475 782</b>	<b>2 290</b>	<b>1 081,13</b>
Belfort	EcoCampus F	gn	PCS	545 449	2 531	216	481 502	2 341	206	666 526	2 290	291
Belfort	EcoCampus A et B	gn	PCS	531 130	2 531	210	468 862	2 341	200	649 029	2 290	283
Belfort	EcoCampus C	gn	PCS	847 090	2 531	335	747 779	2 341	319	582 388	2 290	254
Belfort	EcoCampus E	gn	PCS	336 607	2 531	133	297 144	2 341	127	411 326	2 290	180
Belfort	EcoCampus D	gn	PCS	136 265	2 531	54	120 290	2 341	51	166 513	2 290	73
Belfort	Tech2Co	SST	UTILE	449 684	2 531	<b>177,67</b>	272 694	2 341	<b>116,49</b>	310 142	2 290	<b>135,43</b>
Belfort	INSPE Belfort	gn T2	PCS	291 761	2 531	<b>115,27</b>	301 058	2 341	<b>128,60</b>	174 700	2 290	<b>76,29</b>
Belfort	BU Belfort	gn T3	PCS	547 346	2 531	<b>216,26</b>	449 655	2 341	<b>192,08</b>	433 309	2 290	<b>189,22</b>
Montbéliard	Résidence Portes du Jura	RCU	UTILE	243 397	2 531	<b>96,17</b>	194 000	2 341	<b>82,87</b>	130 474	2 290	<b>56,98</b>
Montbéliard	RU Portes du Jura	RCU	UTILE	453 123	2 531	<b>179,03</b>	376 577	2 341	<b>160,86</b>	357 310	2 290	<b>156,03</b>
Montbéliard	Résidence Rene Thom	gn T3	PCS	563 462	2 531	<b>222,62</b>	417 409	2 341	<b>178,30</b>	438 170	2 290	<b>191,34</b>
Belfort	<b>Résidence + RU Duvillard</b>	<b>gn T3</b>	PCS	<b>1 107 464</b>	<b>2 531</b>	<b>438</b>	<b>799 956</b>	<b>2 341</b>	<b>342</b>	<b>1 256 346</b>	<b>2 290</b>	<b>549</b>
Belfort	Résidence Duvillard	gn T3	PCS	974 041	2 531	385	706 908	2 341	302	921 361	2 290	402
Belfort	RU Duvillard			133 423	2 531	53	93 048	2 341	40	334 985	2 290	146
Belfort	Résidence Fernand Braudel	gn	PCS	11 010	2 531	<b>4,35</b>	8 400	2 341	<b>3,59</b>	9 488	2 290	<b>4,14</b>

consommation totale :	9 620 715	2 531	<b>3 801</b>	7 835 887	2 341	<b>3 347</b>	7 982 073	2290	<b>3 485,62</b>
-----------------------	-----------	-------	--------------	-----------	-------	--------------	-----------	------	-----------------