

ROUTINE TEST PERFORMED

TIGHTNESS TEST 1.25NL mbar/s-HELIUM	IEC 62271-200
MECHANICAL PERFORMANCE CHECKING	IEC 62271-102-103-200
ELEC.SCHEME AND DOCUMENTATION CHECKING	IEC 62271-200
AUX.CIRC.DIELECT.STRENGTH TEST 2kV 1'	IEC 62271-200
VELOCITY TEST Cosmos L-B 400	IEC 62271-103
VISUAL INSPECTION	IEC 62271-200
MAIN CIRCUIT POWER FREQ. TEST 50 kV 1'	IEC 62271-200
DISCONNECTOR POWER FREQ.TEST 50 kV 1'	IEC 62271-102
CAPACITIVE VOLTAGE INDICATOR VPIS	IEC 62271-206
CONTACT RESISTANCE MEASUREMENT TEST	IEC 62271-200

SERIAL NUMBER: **86448301**

ORMAZABAL

Dénomination: cgmcosmos-egd(l) Notice:IG-143

Désign: cgmcosmos-l

Norme: IEC 62271-200-102-103-206

Ur:24kV Up:125kV Ud:50kV fr:50Hz

Ir: 400 A Classe: E3-M1

Ik-Ip: 12,5-31 kA tk:1 s

Pre: 25 kPa Pme: 15 kPa


SF6:0.44kg Année: 2024 TC:-15°C

CO2e:14.58t

Ormazabal y Cia B°Basauntz 2 IGORRE (Bizkaia) Spain

We, Ormazabal y Cia, S.L.U., B° Basauntz, 2 48140 IGORRE (Vizcaya)
- Spain, hereby certify that we are the manufactures of the above
mentioned material.

Management Systems



Date of issue in Igorre,05-12-2024

ROUTINE TEST PERFORMED

TIGHTNESS TEST 1.25NL mbar/s-HELIUM	IEC 62271-200	<input checked="" type="checkbox"/>
MECHANICAL PERFORMANCE CHECKING	IEC 62271-102-103-200	<input checked="" type="checkbox"/>
ELEC.SCHEME AND DOCUMENTATION CHECKING	IEC 62271-200	<input checked="" type="checkbox"/>
VISUAL INSPECTION	IEC 62271-200	<input checked="" type="checkbox"/>
AUX.CIRC.DIELECT.STRENGTH TEST 2kV 1'	IEC 62271-200	<input checked="" type="checkbox"/>
VELOCITY TEST Cosmos L-B 400	IEC 62271-103	<input checked="" type="checkbox"/>
MAIN CIRCUIT POWER FREQ. TEST 50 kV 1'	IEC 62271-200	<input checked="" type="checkbox"/>
DISCONNECTOR POWER FREQ.TEST 50 kV 1'	IEC 62271-102	<input checked="" type="checkbox"/>
CAPACITIVE VOLTAGE INDICATOR VPIS	IEC 62271-206	<input checked="" type="checkbox"/>
CONTACT RESISTANCE MEASUREMENT TEST	IEC 62271-200	<input checked="" type="checkbox"/>

SERIAL NUMBER: 86448302

ORMAZABAL
Dénomination: cgmcosmos-egd(I) Notice:IG-143
Désign: cgmcosmos-I
Norme: IEC 62271-200-102-103-206
Ur:24kV Up:125kV Ud:50kV fr:50Hz
Ir: 400 A Classe: E3-M1
Ik-Ip: 12,5-31 kA tk:1 s
Pre: 25 kPa Pme: 15 kPa
SF6:0.44kg Année: 2024 TC:-15°C
CO2e:14.58t
Ormazabal y Cia B°Basauntz 2 IGORRE (Bizkaia) Spain

We, Ormazabal y Cia, S.L.U., B° Basauntz, 2 48140 IGORRE (Vizcaya)
- Spain, hereby certify that we are the manufactures of the above
mentioned material.

Management Systems



Date of issue in Igorre,05-12-2024

ROUTINE TEST PERFORMED

TIGHTNESS TEST 1,25 NP-ND mbar/s-HELIUM	IEC 62271-200	<input checked="" type="checkbox"/>
FUSE-TRIP AUXI.CONTACTS CHECKING	(INTERNO)-(INTERNAL)	<input checked="" type="checkbox"/>
FUSE TRIPPING CHECKING-AR MECHANISM	IEC 62271-105	<input checked="" type="checkbox"/>
ELEC.SCHEME AND DOCUMENTATION CHECKING	IEC 62271-200	<input checked="" type="checkbox"/>
MECHANICAL PERFORMANCE CHECKING	IEC 62271-102-103-200	<input checked="" type="checkbox"/>
VISUAL INSPECTION	IEC 62271-200	<input checked="" type="checkbox"/>
P.FREQ.TEST TRIPPING COIL-10 kV. 1'	IEC 62271-200	<input checked="" type="checkbox"/>
COIL CHECKING 220VAC-187VAC	IEC 62271-103	<input checked="" type="checkbox"/>
AUX.CIRC.DIELECT.STRENGTH TEST 2kV 1'	IEC 62271-200	<input checked="" type="checkbox"/>
VELOCITY TEST Cosmos P470-AR	IEC 62271-103	<input checked="" type="checkbox"/>
MAIN CIRCUIT POWER FREQ. TEST 50 kV 1'	IEC 62271-200	<input checked="" type="checkbox"/>
DISCONNECTOR POWER FREQ.TEST 50 kV 1'	IEC 62271-102	<input checked="" type="checkbox"/>
CAPACITIVE VOLTAGE INDICATOR VPIS	IEC 62271-206	<input checked="" type="checkbox"/>
CONTACT RESISTANCE MEASUREMENT TEST	IEC 62271-200	<input checked="" type="checkbox"/>

SERIAL NUMBER: 86448303

ORMAZABAL
Dénomination: cgmcosmos-egd(p)
Désign: cgmcosmos-p
Norme: IEC 62271-200-102-103-105-206
Ur: 24kV Up:125kV Ud: 50 kV fr:50Hz
Ir:400A (Départ:200 A) Classe: E3-M1
Ik-Ip:12,5-31kA (Aval fusibles:1-2,5 kA) tk:1 s
Pre: 25 kPa
SF6:1.22kg Pme:15kPa Année: 2024 TC: -15 °C
CO2e:29.64t
Ormazabal y Cia B°Basauntz 2 IGORRE (Bizkaia)Spain

We, Ormazabal y Cia, S.L.U., B° Basauntz, 2 48140 IGORRE (Vizcaya)
- Spain, hereby certify that we are the manufactures of the above
mentioned material.

Management Systems



Date of issue in Igorre,05-12-2024