



Institut de Recherche
pour le Développement
IRD

B6AM



COF 02 - PLAN DE COFFRAGE

[illegible]

HYPOTHESE DE CALCUL	
CARACTERISTIQUES DU SOL	
- Contraintes au rapport de sol G _z /P ₀ de 265,5/600 du 0,6/0,975/60	
- Contrainte admissible: 275 kPa	
- Semelles isolées: 275 kPa	
- Tassements / tassements différentiels :	
- Semelles isolées : 1,4 cm et 1 à 2,4 cm	
CARACTERISTIQUES DES MATERIAUX	
- Fondation béton C30/37 - XC2	
- Gros lédon béton C16/20 - XC3	
- Superstructure béton C25/30 - XC3	
- Superstructure dall. béton C25/30 - XC3	
- Acier S200 MPa - Classe B	
- Recouvrement des aciers S200	
CHARGES ET SURCHARGES	
- Surcharge d'exploitation	2500 daN/m²
- Charge d'entretien	150 daN/m²
- Charpente/cimentaire	120 daN/m²
- Oléage/Caraillage	120 daN/m²
- Râble cruce 600:	320 daN/m²
- Râble spiralé:	100 daN/m²
- Fosse spirale 600:	100 daN/m²
- Fosse cylindrique	100 daN/m²
- Isolatant	245 daN/m²
Charge d'exploitations	
- Stockage C.A.C.	500 daN/m²
- Toiture	100 daN/m²
EMBOITAGE	
- Enrobage fondations:	50 mm
- Enrobage superstructure:	50 mm

Architectural floor plan of a building. The plan shows a kitchen (Cuisine) at the top right, and three living areas (Lg 30x30 ht As: 0.00) below it. The plan includes dimensions, level markers, and a section line A-A. A note indicates "Poteaux à remplacer" (beams to be replaced) along the right edge.

Technical drawing of a reinforced concrete slab (dalles) showing dimensions and reinforcement details.

Dimensions:

- Overall length: 3.00 m
- Overall width: 1.70 m
- Reinforcement bar spacing: 60 cm
- Reinforcement bar diameter: 30 mm

Reinforcement Details:

- Reinforcement bars: Lg 30x30 ht As: 0.00
- Reinforcement bars are shown in a grid pattern.

Labels:

- Semelles à créer (Foundations to be created)
- Béton de propreté (Clean concrete)
- Film polyane (Polyane film)

VUE EN PLAN PROJET
Ech : 1/50